




322/758/321/2018

Gdańsk, 05-09-2018

## HYGIENIC CERTIFICATE No 316/322/321/2018

- 1. Name of product (material)** DUROPAL-HPL - PN EN 438  
thickness ranges: 0,2 ÷ 1,0 mm
- 2. Application** worktops, furniture production and interior's decorate
- 3. Applicant institution** Pfleiderer Polska Spółka z o.o.  
Strzegomska 42AB St  
PL-53-611 Wrocław
- 4. Manufacturer** Pfleiderer Arnsberg GmbH  
Westring 19-21  
DE-59759 Arnsberg
- 5. The product meets the requirements of hygiene on the following conditions:**
  - Load the material 1,35 m<sup>2</sup>/m<sup>3</sup> of cubic living quarters, dedicated to permanent residence ill health buildings, children and young people in educational buildings and also places destined for food storage – hereinafter referred to as the “places of A category”
  - Load the material 2,7 m<sup>2</sup>/m<sup>3</sup> of cubic of rooms in public buildings other than those listed above and the side rooms in apartments - hereinafter referred to as the “places of B category” according to Regulation of Minister of Health and Social Care dated on 12<sup>th</sup> March 1996, - M.P. 1996 No 19 poz.231.

The certificate does not concern working conditions and occupational hygiene during the assembly of product. Facilities that use the product should be ventilated until the odor disappears.
- 6. Basis of certificate:** applications of OB-RPPD LB/452/845/18 of August 21,2018, Certificate of Examination No 7627/26/2018 of August 17,2018 issued by Research & Development Centre for Wood - Based Panels in Czarna Woda.  
Hygienic class E1.
- 7. The present certificate may be changed or voided if either party presents sufficient evidence.**  
This certificate expires after 5 years from the date of issuing or if any changes either in composition or manufacturing technology of the product have been introduced.

KIEROWNIK  
Zakładu Toksykologii Środowiska  
  
prof. dr hab. Lidia Wolska